

ADDENDUM NO. 1
Tank Painting/Interior Repair CDBG Project
Washington Terrace City

The following changes and clarifications are hereby made to the above referenced project:

1. Specification-Exterior Finishes for Previously Painted Steel Tank

- a. Spot Prime (Macropoxy 646 Fast Cure Epoxy Part A Mill White, or equivalent)
- b. Full Coat (Macropoxy 646 Fast Cure Epoxy Part A Mill White, or equivalent)
- c. Full Finish Coat (Hi Solids Polyurethane Gloss (Part S) Extra White/Tint Base Part S, or equivalent)

2. Specification-Small Area Interior Repair

- a. Surface Preparation: Prepare in accordance with SSPC-SP11 Power Tool Cleaning to Bare Metal to create a minimum 2.0 mil profile.
- b. Solvent wipe with suitable Tnemec solvent, or equivalent, after surface preparation and prior to the application of the repair coating.
- c. Feather all rough edges, with sandpaper, scotch brite, etc. Tape off the surrounding area to prevent coating application onto unprepared areas.
- d. Finish: Series FC22 Touch-up kits, or approved equivalent, applied in accordance to attached application guide.

This Addendum is hereby attached to and made part of the Contract Documents and each Bidder shall acknowledge receipt of this Addendum in his Bid.

By: _____

Shane K. Taggart, P.E.

Jones & Associates Consulting Engineers

Date: 9/4/2019