



**ADDENDUM #1 – November 4<sup>th</sup>, 2024  
SOUTH WILLARD CRACK SEAL PROJECT**

**Questions & Answers**

- **What size of crack needs to be sealed?**
  - Any cracks 1/8" and wider shall be filled.
- **Can you please confirm the mailing address for the bids?**
  - Box Elder County Road Shed
    - 5730 W 8800 N Tremonton, UT 84337
- **Can you confirm if the listed sq yd on items 7, 12, 13, 14, 15, 19 include the crack seal along the curb?**
  - To clarify, the listed square yardage associated with each bid list item represents an estimated area of all the asphalt in that road section. It is not an estimated portion of that section that is needing crack seal. We strongly encourage the Bidder to visit the site in order to appropriately estimate the amount of crack seal needed for each road section.
  - Items #7, 12, 13, 14, 15, and 19 indicate in their description that those road sections will need crack seal along the lip of the curb in addition to what is needed in the roadway.

This Addendum is hereby attached to and made part of the Bidding Documents and each Bidder shall acknowledge receipt of this Addendum on the Bid Form.

**Project Engineer:** Steven Brady  
Jones & Associates  
6080 Fashion Point Drive  
South Ogden, UT 84405  
[www.jonescivil.com](http://www.jonescivil.com)